

**CHIMNEY SWEEP AND LEVEL ONE INSPECTION**

Appliance Service Record

**HIGH MOUNTAIN HEARTH SOLUTIONS, INC.**  
 18573 G RD  
 DELTA, CO 81416  
 970-874-4328 (HEAT)



**Woodcreek Lodge**

Unit Number	Date/Time	Type of Appliance and Chimney
204	04/23/2019	Manufactured Fireplace and Chimney

**Photo**



**MANUFACTURED FIREPLACE**

Each component is inspected and serviced as needed to ensure safe and proper operation

	Acceptable	Unacceptable	Not Applicable	Comments
Firebox	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	
Refractory	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	
Doors	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	
Damper	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	
Hearth Extension	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	
Clearance to Combustibles	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	Installed 2 heat shields to provide adequate clearance to sidewalls.

**MANUFACTURED CHIMNEY**

Each component is inspected and serviced as needed to ensure safe and proper operation

	Acceptable	Unacceptable	Not Applicable	Comments
Height	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	
Condition	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	
Chimney Cap	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	

**INSPECTION CONCLUSION**

**Results**

Performed Chimney Sweep and Level I Inspection, and ensured chimney is free of dangerous creosote deposits. All conditions satisfactory.

**Comments:**

--

*Powered by [www.doForms.com](http://www.doForms.com)*