

CHIMNEY SWEEP AND LEVEL ONE INSPECTION

Appliance Service Record

HIGH MOUNTAIN HEARTH SOLUTIONS, INC.
 18573 G RD
 DELTA, CO 81416
 970-874-4328 (HEAT)



Woodcreek Lodge

Unit Number	Date/Time	Type of Appliance and Chimney
305	04/24/2019	Manufactured Fireplace and Chimney

Photo



MANUFACTURED FIREPLACE

Each component is inspected and serviced as needed to ensure safe and proper operation

	Acceptable	Unacceptable	Not Applicable	Comments
Firebox	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	
Refractory	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	Installed new refractory.
Doors	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	
Damper	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	Repaired damper chain
Hearth Extension	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	
Clearance to Combustibles	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	Installed heat shield to bring sidewall clearance up to code.

MANUFACTURED CHIMNEY

Each component is inspected and serviced as needed to ensure safe and proper operation

	Acceptable	Unacceptable	Not Applicable	Comments
Height	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	
Condition	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	
Chimney Cap	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	

INSPECTION CONCLUSION

Results

Performed Chimney Sweep and Level I Inspection, and ensured chimney is free of dangerous creosote deposits. All conditions satisfactory.

Comments:

--

Powered by www.doForms.com