

## CHIMNEY SWEEP AND LEVEL ONE INSPECTION

Appliance Service Record

**HIGH MOUNTAIN HEARTH SOLUTIONS, INC.**  
 18573 G RD  
 DELTA, CO 81416  
 970-874-4328 (HEAT)



### Woodcreek Lodge

Unit Number	Date/Time	Type of Appliance and Chimney
301	04/22/2019	Manufactured Fireplace and Chimney

#### Photo



#### MANUFACTURED FIREPLACE

Each component is inspected and serviced as needed to ensure safe and proper operation

	Acceptable	Unacceptable	Not Applicable	Comments
Firebox	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	
Refractory	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	
Doors	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	
Damper	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	
Hearth Extension	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	
Clearance to Combustibles	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	Installed shield on side wall to provide adequate clearance.

#### MANUFACTURED CHIMNEY

Each component is inspected and serviced as needed to ensure safe and proper operation

	Acceptable	Unacceptable	Not Applicable	Comments
Height	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	
Condition	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	
Chimney Cap	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	

#### INSPECTION CONCLUSION

##### Results

Performed Chimney Sweep and Level I Inspection, results are not satisfactory. See comments below.

##### Comments:

--

*Powered by [www.doForms.com](http://www.doForms.com)*